


# Results of tests conducted at the Institute for Window Technology **ift Rosenheim** (Germany)



Air permeability according to  
EN 12207:1999-11

**Class 4**



Operating forces according to  
EN 13115:2001-07

**Class 1**



Watertightness according to  
EN 12208:1999-11

**Class 7A**



Mechanical durability  
according to EN 12400:2002-10

**Class 2**



Resistance to wind load according to  
EN 12210:1999-11/AC:2002-08

**Class C3 / B3**



Impact resistance according to  
EN 13049:2003-04

**Class 3**



Certificate  
**ISO 9001:2008**