

COCREATION GRASS (HONGKONG) CO., LIMITED

UNIT 2, (S) LG1, MIRROR TOWER, 61 MODY ROAD, TSIM SHA TSUI, KOWLOON, HONG KONG

Sample Name : ELLAGRASS**Style/Item No.** : /

The above sample(s) data and information was / were submitted and identified on behalf of the client. SGS is not responsible for the authenticity, integrity and results of the data and information and / or the validity of the conclusion arising therefrom. Results apply to the sample as received.

SGS Ref. No. : NJIN2510001829PL01**Sample Receiving Date** : Oct 14,2025**Testing Period** : Oct 14,2025 to Oct 22,2025**Test Required** : EN 13501-1:2018 Fire classification of construction products and building elements Part 1: Classification using data from reaction to fire tests.**Test result(s)** : See attached sheet

Signed for and on behalf of
SGS-CSTC Standards Technical Services Co., Ltd Anji Branch



Echo Li
Approved signatory



SGS-CSTC Standards Technical Services Co., Ltd.
Anji Branch Fire Technology Service

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

No. 301, Sunlight Road, 2 Block, Sunlight Industry Zone, Anji County, Zhejiang Province, China 313300 t (86-572) 5018825 f (86-572) 5018829 www.sgs.com.cn
中国·浙江·安吉县阳光工业园二区阳光大道301号 邮编: 313300 t (86-572) 5018825 f (86-572) 5018829 sgs.china@sgs.com

I. Test conducted

This test was conducted as per EN 13501-1:2018 Fire classification of construction products and building elements – Part 1: Classification using data from reaction to fire tests. And the test methods as following: EN ISO 11925-2:2020 Reaction to fire tests - Ignitability of products subjected to direct impingement of flame - Part 2: Single-flame source test.

II. Details of classified product

Sample description	Grass
Color	Green
Sample size	EN ISO 11925-2: 250mm×90mm
Thickness	15.0mm
Mass per unit area	1.6 kg/m ²
Test surface	Grass surface

III. Test results

Test method	Parameter	Number of tests	Results
EN ISO 11925-2 Exposure = 15 s	Whether vertical flame spread (Fs) in excess of 150 mm within 20 s (Yes/No)	6	No
	Ignition of the filter paper (Yes/No)		No

IV. Classification and direct field of application

a) Reference of classification

This classification has been carried out in accordance with **EN 13501-1:2018**.

b) Classification

The product, Grass, in relation to its reaction to fire behaviour is classified:

Fire behaviour
E _{fl}

Reaction to fire classification: E_{fl}

Remark: The classes with their corresponding fire performance are given in annex A.



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

No. 301, Sunlight Road, 2 Block, Sunlight Industry Zone, Anji County, Zhejiang Province, China 313300 t (86-572) 5018825 f (86-572) 5018829 www.sgs.com.cn
 中国·浙江·安吉县阳光工业园二区阳光大道301号 邮编: 313300 t (86-572) 5018825 f (86-572) 5018829 sgs.china@sgs.com

Statement:

This declaration of conformity is only based on the result of this laboratory activity, the impact of the uncertainty of the results was not included.

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test; they are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.

Warning:

This classification report does not represent type approval or certification of the product.

The test laboratory has, therefore, play no part in sampling the product for the test, although it holds appropriate references to the manufacturer's factory production control that is aimed to be relevant to the samples tested and that will provide for their traceability.



Annex A

Classes of reaction to fire performance for floorings


Class	Test methods	Classification	Additional classification
A _{1fl}	EN ISO 1182 ^a and	$\Delta T \leq 30^\circ\text{C}$, and $\Delta m \leq 50\%$, and $t_f = 0$ (i.e. no sustained flaming)	-
	EN ISO 1716	PCS $\leq 2.0\text{MJ/kg}$ ^a and PCS $\leq 2.0\text{MJ/kg}$ ^b and PCS $\leq 1.4\text{MJ/m}^2$ ^c and PCS $\leq 2.0\text{MJ/kg}$ ^d	-
A _{2fl}	EN ISO 1182 ^a or	$\Delta T \leq 50^\circ\text{C}$, and $\Delta m \leq 50\%$, and $t_f \leq 20\text{s}$	-
	EN ISO 1716 and	PCS $\leq 3.0\text{MJ/kg}$ ^a and PCS $\leq 4.0\text{MJ/m}^2$ ^b and PCS $\leq 4.0\text{MJ/m}^2$ ^c and PCS $\leq 3.0\text{MJ/kg}$ ^d	-
	EN ISO 9239-1 ^e	Critical flux ^f $\geq 8.0\text{kW/m}^2$	Smoke production ^g
B _{fl}	EN ISO 9239-1 ^e and	Critical flux ^f $\geq 8.0\text{kW/m}^2$	Smoke production ^g
	EN ISO 11925-2 ^h Exposure = 15s	F _s $\leq 150\text{mm}$ within 20 s	-
C _{fl}	EN ISO 9239-1 ^e and	Critical flux ^f $\geq 4.5\text{kW/m}^2$	Smoke production ^g
	EN ISO 11925-2 ^h Exposure = 15s	F _s $\leq 150\text{mm}$ within 20 s	-
D _{fl}	EN ISO 9239-1 ^e and	Critical flux ^f $\geq 3.0\text{kW/m}^2$	Smoke production ^g
	EN ISO 11925-2 ^h Exposure = 15s	F _s $\leq 150\text{mm}$ within 20 s	-
E _{fl}	EN ISO 11925-2 ^h Exposure = 15s	F _s $\leq 150\text{mm}$ within 20 s	-
F _{fl}	EN ISO 11925-2 ^h Exposure = 15s	F _s $> 150\text{mm}$ within 20 s	-

^a For homogeneous products and substantial components of non-homogeneous products.
^b For any external non-substantial component of non-homogeneous products.
^c For any internal non-substantial component of non-homogeneous products.
^d For the product as a whole.
^e Test duration = 30 min.
^f Critical flux is defined as the radiant flux at which the flame extinguishes or the radiant flux after a test period of 30 min, whichever is the lower (i.e. the flux corresponding with the furthest extent of spread of flame).
^g **s1** = Smoke $\leq 750\%$ minutes;
s2 = not s1.
^h Under conditions of surface flame attack and, if appropriate to the end use application of the product, edge flame attack.



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com
 No. 301, Sunlight Road, 2 Block, Sunlight Industry Zone, Anji County, Zhejiang Province, China 313300 t (86-572) 5018825 f (86-572) 5018829 www.sgs.com.cn
 中国·浙江·安吉县阳光工业园二区阳光大道301号 邮编: 313300 t (86-572) 5018825 f (86-572) 5018829 sgs.china@sgs.com

Photo Appendix:



SGS authenticate the photo on original report only

End of Report



SGS-CSTC Standards Technical Service Co., Ltd.
Anji Branch Inspection & Testing Service

Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com
No. 301, Sunlight Road, 2 Block, Sunlight Industry Zone, Anji County, Zhejiang Province, China 313300 t (86-572) 5018825 f (86-572) 5018829 www.sgs.com
中国·浙江·安吉县阳光工业园二区阳光大道301号 邮编: 313300 t (86-572) 5018825 f (86-572) 5018829 sgs.china@sgs.com